

Generator Set Specifications

Minimum Rating	400 kVA
Maximum Rating	400 kVA
Emissions/Fuel Strategy	Non Regulated
Voltage	200 to 400 Volts
Frequency	50 Hz
Duty Cycle	Standby, Prime

Engine Specifications

Aspiration	Turbocharged, Air to Air Aftercooled
------------	--------------------------------------

C13 | DE400E0 Standard Equipment

Control Panel

GCCP Control panel

Alternator And Alternator Attachments

12 Leads

IP23 Protection

Voltage regulator (single phase sensing)

C13 | DE400E0 Optional Equipment

Control Panel

GCCP Control panel

Earth fault and earth leakage